

## **Well Flooding**

In general, if floodwaters have reached your well, or if you notice any change in the appearance or taste of your water, or even if you are unsure about the impact of flooding on the water quality in your area, you should boil all of the water used for drinking, making beverages or ice, cooking, brushing your teeth, washing dishes and washing areas of the skin that have been cut or injured (be sure to cool the water first). The water should be brought to a rolling boil for at least one full minute. Bottled water may also be used for these purposes.

If your well has been flooded, you must first disinfect it and contact the Health Department for information on how to sample your water, and where to bring the for bacteriological testing. It is important to disinfect both the well and all of the household plumbing to assure that all the infectious agents are killed. Both the amount of chlorine and the amount of time you allow it to remain in your system are important considerations. If the water is discolored, run the water until it is clear before starting the disinfection process.

## **Well Disinfection**

Well disinfection can eliminate or reduce many kinds of harmful bacteria and viruses as well as non-harmful bacteria which can cause unpleasant taste and odors. However, disinfection will not correct water problems caused by chemical contamination from nitrate, fuels, pesticides, or other substances.

Well disinfection should be performed under the following circumstances:

- When coliform bacteria are present in the water
- After flooding of the well
- After plumbing installation, e.g. softeners, sinks, filters
- After casing or pump repairs - submersible types or other
- When drinking water tastes or odors change, e.g. from iron or sulfur reducing bacteria
- As part of annual maintenance
- During startup of seasonal wells

## **Electrical Safety**

EXTREME CAUTION is advised as you will be working with electricity and water. Potentially lethal voltages exist - if you are not acquainted with working with electricity, seek professional advice.

Your safety precautions should include:

- Turn off the pump circuit breaker before removing the well cap
- While the breaker is off, examine for chafed wire insulation or missing wire nuts and repair as necessary
- Wear rubber soled shoes or boots, preferably waterproof.

## **Chemical**

Severe eye damage may result from contact with chlorine, including bleach and highly chlorinated household water.

Users of the water must be warned to not drink or bathe with the water while chlorine is still present in the system

Do not leave bleach jugs lying around - ingestion of bleach is the most common toxic exposure for children in the U.S.

Wear protective goggles or a face shield when working with the bleach.

## **Respiratory**

Well pits pose an extreme hazard as they frequently contain a build-up of toxic gases or simply lack oxygen to sustain life.

DO NOT ENTER WELL PITS. Death can occur in even a shallow well pit

Leave disinfection of wells in pits to licensed well or pump contractors.

## **Procedure**

Step 1 - Isolate Critical Areas Bypass softeners, bait tanks, livestock, and anything else that might be vulnerable to chlorine to prevent damage to the device or animals. This would also be a good time to install a new filter element if the water system has any present.

Since softeners themselves may be a source of contamination, it is good to disinfect the softener at the same time the well is being disinfected. See the end of this document for a softener disinfection procedure.

Step 2 - Electrical Safety Turn off electrical power to the pump. If the breaker box has a "lockout" hasp to prevent someone from accidentally turning on the water pump circuit breaker, use it.

Step 3 - Remove well seal/cap NOTE: the procedure shown is to be used for a centrifugal pump system and not for a submersible pump system connected at the top of the well and it is recommended that a well that is using a submersible pump should be disinfected by a certified well contractor.

This is a northern well and is not typical of the wells we have here in Florida.

With electrical power off, remove the well cap and lift the wires/wire nuts out and pull to the side.

Step 4 - Mixing a chlorine solution Add a half gallon of bleach to a clean pail with about 3 gallons of water. This is generally sufficient to disinfect a 4 inch diameter well 100 feet deep or less. For wells greater than 100 feet deep or with a larger casing diameter, increase the amount of bleach proportionately.

If you have a dug well with a diameter greater than 18 inches, use 2 to 4 gallons of bleach added directly to the well. Please note that many dug wells are difficult or impossible to disinfect due to their unsanitary construction.

Step 5 - Adding chlorine to the well Pour the mixture into the well.

Step 6 - Recirculating chlorinated water Recirculation of chlorinated water helps to wash down the sidewalls of the well casing, mix the water column thoroughly, and distribute the chlorine.

Place garden hose into well casing

Turn on pump power

Run garden hose from the water system and put it back into the casing to recirculate water. Recirculate this for about 2 hours after the chlorine smell appears from the garden hose.

You may notice that the water coming from the garden hose turns reddish for a brief period. This is due to the chlorine precipitating iron in the water. If the water appears excessively red and cloudy from this reaction, discharge the hose outside of the casing until the water runs clear.

Step 7 - Bringing chlorine to each faucet While water is circulating, run water from each fixture\* one at a time until you smell bleach (or use chlorine test papers), then close the faucet.

Do this for each faucet, including:

- cold and hot water taps
- toilets and shower/bath fixtures
- any outside faucets or yard hydrants
- \*Faucet aerators may need to be removed if clogging occurs from precipitated iron.

(Chlorine test papers, such as those commonly used in restaurants to check chemical sanitizing dishwashers, are not necessary but provide a visual indication that chlorine is present.)

Step 8 - Removing the chlorinated water Let system set overnight with chlorine in the water lines. In the morning, run a garden hose to flush out the system

Since chlorine will kill vegetation, direct the water to an area where it won't matter if plants are harmed.

Do not run the water into your septic system as the amount of water required to flush the system may hydraulically overload the septic system

TOTAL chlorine must be absent prior to taking water samples for coliform analysis. While this test isn't necessary for the homeowner, be aware that any amount of chlorine left in the system may erroneously result in a negative coliform test.

When a chlorine test kit is unavailable, wait a few days after the last trace of chlorine odor has been smelled before submitting a water sample for coliform analysis. This will ensure a valid test result.

### **Disinfection Issues Expectations and Concerns**

It may take as little as half an hour or as much as 4 days to completely remove the chlorine odor from the water system. This is dependent upon many factors including the height of the water column in the casing, well drawdown, pump capacity, etc. To facilitate faster removal of the chlorine in stubborn cases, a hose splitter may be attached and one hose run back into the casing and the other hose pumped to waste.

Water heaters take a long time to flush out once chlorine has been introduced into them. Do not shower/bathe with water containing high levels of chlorine due to the possibility of damaging your eyes.

It is not unusual to require 2, 3, 4, or more disinfections to clear water systems of coliform bacteria that have been growing in the system for a period of time. If the well refuses to clear, a licensed well driller should be enlisted to utilize special techniques and equipment to flush the well. It is essential that any water system defects that could allow surface water to enter the well be corrected.

Plumbing grit and precipitated minerals may form when the chlorine is added to the system. This grit can cause clogging with faucet aerators, flush valves, water solenoids, and equipment using filters.

**Softener Disinfection** Water softeners may be damaged by excessive amounts of chlorine but the softener itself should be chlorinated when there are bacteria problems. Follow the manufacturer's instructions for disinfecting the particular unit you have, or use this procedure:

During the disinfection process, turn softener to 'Bypass' once chlorine is first smelled in a softened water tap.

Keep unit on bypass until chlorine is flushed out of the system

To disinfect the softener, add ½ cup bleach to the brine tank and regenerate the unit

### **Follow-up**

Frequently, coliform bacteria will regrow in the water system after about a month. For this reason, it is important to retest in approximately 30 days after disinfection. If coliform is again detected, disinfect the well using the same procedure.